




**Circuit-breaker, 3p, 630A, withdrawable unit**

**Part no. NZMH3-AE630-AVE**  
**Catalog No. 110851**



Similar to illustration


**Delivery program**

|   |                          |    |  |   |
|---|--------------------------|----|--|---|
| Product range   |                          |    |  | Circuit-breaker                               |
| Protective function   |                          |    |  | System and cable protection                   |
| Standard/Approval   |                          |    |  | IEC   |
| Installation type   |                          |    |  | Withdrawable                                  |
| Release system  |                          |    |  | Electronic release                            |
| Construction size   |                          |    |  | NZM3  |
| Description   |                          |    |  | R.m.s. value measurement and "thermal memory" |
| Number of poles   |                          |    |  | 3 pole  |
| Standard equipment  |                          |    |  | Screw connection                              |
| <b>Switching capacity</b>   |                          |    |  |   |
| 400/415 V 50 Hz   | $I_{cu}$                 | kA |  | 150   |
| <b>Rated current = rated uninterrupted current</b>                                  |                          |    |  |   |
| Rated current = rated uninterrupted current   | $I_n = I_u$              | A  |  | 630   |
| <b>Setting range</b>  |                          |    |  |   |
| Overload trip   |                          |    |  |   |
|  | $I_r$                    | A  |  | 315 - 630                                     |
| Short-circuit releases  |                          |    |  |   |
|  |                          |    |  |   |
| Non-delayed   | $I_i = I_n \times \dots$ |    |  | 2 - 8   |
|  |                          |    |  |   |

**Technical data**

**General**

|   |  |      |  |  |
|---|--|------|--|--|
| Standards   |  |      |  | IEC/EN 60947   |
| Protection against direct contact   |  |      |  | Finger and back of hand proof to VDE 0106 Part 100                             |
| Climatic proofing   |  |      |  | Damp heat, constant, to IEC 60068-2-78<br>Damp heat, cyclic, to IEC 60068-2-30 |
| Ambient temperature   |  |      |  |  |
| Ambient temperature, storage  |  | °C   |  | - -40 - + 70   |
| Operation   |  | °C   |  | -25 - +70  |
| Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27 |  | g    |  | 20 (half-sinusoidal shock 20 ms)   |
| Safe isolation to EN 61140  |  |      |  |  |
| Between auxiliary contacts and main contacts  |  | V AC |  | 500  |
| between the auxiliary contacts  |  | V AC |  | 300  |
| Weight  |  | kg   |  | 6.34   |
| Mounting position   |  |      |  | Vertical and 90° in all directions   |



With XFI earth-fault release:

- NZM1, N1, NZM2, N2: vertical and 90° in all directions with plug-in unit
- NZM1, N1, NZM2, N2: vertical, 90° right/left with withdrawable unit:
- NZM3, N3: vertical, 90° right/left

- NZM4, N4: vertical  
with remote operator:  
- NZM2, N(S)2, NZM3, N(S)3,  
NZM4, N(S)4: vertical and 90° in all  
directions

|  |  |  |
|--|--|--|
| Direction of incoming supply           |  | as required  |
| Degree of protection                   |  |  |
| Device                                 |  | In the operating controls area: IP20 (basic degree of protection)        |
| Enclosures                             |  | With insulating surround: IP40<br>With door coupling rotary handle: IP66 |
| Terminations                           |  | Tunnel terminal: IP10<br>Phase isolator and strip terminal: IP00         |
| Other technical data (sheet catalogue) |  | Temperature dependency, Derating   |

### Circuit-breakers

|   |             |      |               |
|---|-------------|------|---------------|
| Rated current = rated uninterrupted current | $I_n = I_u$ | A    | 630           |
| Rated surge voltage invariability           | $U_{imp}$   |      |               |
| Main contacts                               |             | V    | 8000          |
| Auxiliary contacts                          |             | V    | 6000          |
| Rated operational voltage                   | $U_e$       | V AC | 690           |
| Overvoltage category/pollution degree       |             |      | III/3         |
| Rated insulation voltage                    | $U_i$       | V    | 1000          |
| Use in unearthed supply systems             |             | V    | $\leq$<br>690 |

### Switching capacity

|   |          |    |   |
|---|----------|----|---|
| Rated short-circuit making capacity             | $I_{cm}$ |    |   |
| 240 V   | $I_{cm}$ | kA | 330   |
| 400/415 V                                       | $I_{cm}$ | kA | 330   |
| 440 V 50/60 Hz                                  | $I_{cm}$ | kA | 286   |
| 525 V 50/60 Hz                                  | $I_{cm}$ | kA | 143   |
| 690 V 50/60 H                                   | $I_c$    | kA | 74  |
| Rated short-circuit breaking capacity $I_{cn}$  | $I_{cn}$ |    |   |
| $I_{cu}$ to IEC/EN 60947 test cycle O-t-CO      | $I_{cu}$ | kA |   |
| 240 V 50/60 Hz                                  | $I_{cu}$ | kA | 150   |
| 400/415 V 50/60 Hz                              | $I_{cu}$ | kA | 150   |
| 440 V 50/60 Hz                                  | $I_{cu}$ | kA | 130   |
| 525 V 50/60 Hz                                  | $I_{cu}$ | kA | 65  |
| 690 V 50/60 Hz                                  | $I_{cu}$ | kA | 35  |
| $I_{cs}$ to IEC/EN 60947 test cycle O-t-CO-t-CO | $I_{cs}$ | kA |   |
| 240 V 50/60 Hz                                  | $I_{cs}$ | kA | 150   |
| 400/415 V 50/60 Hz                              | $I_{cs}$ | kA | 150   |
| 440 V 50/60 Hz                                  | $I_{cs}$ | kA | 130   |
| 525 V 50/60 Hz                                  | $I_{cs}$ | kA | 33  |
| 690 V 50/60 Hz                                  | $I_{cs}$ | kA | 9   |
|   |          |    | Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit-breaker. |
| Rated short-time withstand current              |          |    |   |
| t = 0.3 s                                       | $I_{cw}$ | kA | 3.3   |
| t = 1 s   | $I_{cw}$ | kA | 3.3   |
| Utilization category to IEC/EN 60947-2          |          |    | A   |
| Rated making and breaking capacity              |          |    |   |
| Rated operational current                       | $I_e$    | A  |   |
| AC-1  |          |    |   |
| 380 V 400 V                                     | $I_e$    | A  | 630   |
| 415 V   | $I_e$    | A  | 630   |
| 690 V   | $I_e$    | A  | 630   |
| AC--3   |          |    |   |
| 380 V 400 V                                     | $I_e$    | A  | 450   |

|   |                |       |       |
|---|----------------|-------|-------|
| 415 V   | I <sub>e</sub> | A     | 450   |
| 660 V 690 V   | I <sub>e</sub> | A     | 450   |
| Lifespan, mechanical(of which max. 50 % trip by shunt/undervoltage release) | Operations     |       | 15000 |
| Lifespan, electrical  |                |       |       |
| AC-1  |                |       |       |
| 400 V 50/60 Hz  | Operations     |       | 5000  |
| 415 V 50/60 Hz  | Operations     |       | 5000  |
| 690 V 50/60 Hz  | Operations     |       | 3000  |
| AC--3   |                |       |       |
| 400 V 50/60 Hz  | Operations     |       | 2000  |
| 415 V 50/60 Hz  | Operations     |       | 2000  |
| 690 V 50/60 Hz  | Operations     |       | 2000  |
| Max. operating frequency  |                | Ops/h | 60    |
| Total downtime in a short-circuit   |                | ms    | < 10  |

## Terminal capacity

|   |      |                 |   |
|---|------|-----------------|---|
| Standard equipment  |      |                 | Screw connection  |
| Accessories required                                      |      |                 | NZM3-XAVS   |
| Optional accessories                                      |      |                 | Box terminal<br>Tunnel terminal<br>connection on rear   |
| Round copper conductor                                    |      |                 |   |
| Box terminal  |      |                 |   |
| Solid   |      | mm <sup>2</sup> | 2 x 16  |
| Stranded  |      | mm <sup>2</sup> | 1 x (35 - 240)<br>2 x (25-120)  |
| Tunnel terminal   |      |                 |   |
| Solid   |      | mm <sup>2</sup> | 1 x 16  |
| Stranded  |      | mm <sup>2</sup> |   |
| 1-hole  |      | mm <sup>2</sup> | 1 x (16 - 185)  |
| 2-hole  |      | mm <sup>2</sup> | 1 x (50 - 240)<br>2 x (50 - 240)  |
| Bolt terminal and rear-side connection                    |      |                 |   |
| Direct on the switch                                      |      |                 |   |
| Solid   |      | mm <sup>2</sup> | 1 x 16<br>2 x 16  |
| Stranded  |      | mm <sup>2</sup> | 1 x (25 - 240)<br>2 x (25 - 240)  |
| Connection width extension                                |      | mm <sup>2</sup> |   |
| Connection width extension                                |      | mm <sup>2</sup> | 2 x 300   |
| Al conductors, Cu cable                                   |      |                 |   |
| Solid   |      | mm <sup>2</sup> | 1 x 16  |
| Stranded  |      | mm <sup>2</sup> |   |
| Stranded  |      | mm <sup>2</sup> | 1 x (25 - 185) <sup>2)</sup>  |
| 2-hole  |      | mm <sup>2</sup> | <sup>2)</sup> Up to 240 mm <sup>2</sup> can be connected depending on the cable manufacturer.<br>1 x (50 - 240)<br>2 x (50 - 240) |
| Cu strip (number of segments x width x segment thickness) |      |                 |   |
| Box terminal  |      |                 |   |
|   | min. | mm              | 6 x 16 x 0.8  |
|   | max. | mm              | 10 x 24 x 1.0<br>+ 5 x 24 x 1.0<br>(2 x) 8 x 24 x 1.0   |
| Bolt terminal and rear-side connection                    |      |                 |   |
| Flat copper strip, with holes                             | min. | mm              | 6 x 16 x 0.8  |
| Flat copper strip, with holes                             | max. | mm              | 10 x 32 x 1.0 + 5 x 32 x 1.0  |
| Connection width extension                                |      | mm              | (2 x) 10 x 50 x 1.0   |

|  |      |                 |                                      |
|--|------|-----------------|--------------------------------------|
| Copper busbar (width x thickness)      | mm   |                 |                                      |
| Bolt terminal and rear-side connection |      |                 |                                      |
| Screw connection                       |      |                 | M10                                  |
| Direct on the switch                   |      |                 |                                      |
|  | min. | mm              | 20 x 5                               |
|  | max. | mm              | 30 x 10<br>+ 30 x 5                  |
| Connection width extension             |      | mm              |                                      |
| Connection width extension             | max. | mm              | 2 x (10 x 50)                        |
| Control cables                         |      |                 |                                      |
|  |      | mm <sup>2</sup> | 1 x (0.75 - 2.5)<br>2 x (0.75 - 1.5) |

## Design verification as per IEC/EN 61439


|  |                  |    |  |
|--|------------------|----|--|
| Technical data for design verification   |                  |    |  |
| Rated operational current for specified heat dissipation   | I <sub>n</sub>   | A  | 630  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub> | W  | 119.07   |
| Operating ambient temperature max.   |                  | °C | -25  |
| Operating ambient temperature max.   |                  | °C | 70   |
| IEC/EN 61439 design verification   |                  |    |  |
| 10.2 Strength of materials and parts   |                  |    |  |
| 10.2.2 Corrosion resistance  |                  |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                  |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                  |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                  |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                  |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting   |                  |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact   |                  |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions  |                  |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                  |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances   |                  |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                  |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components   |                  |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections  |                  |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                  |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                  |    |  |
| 10.9.2 Power-frequency electric strength   |                  |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                  |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                  |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                  |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating   |                  |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility  |                  |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function  |                  |    | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |


## Technical data ETIM 6.0

|  |  |    |           |
|--|--|----|-----------|
| Low-voltage industrial components (EG000017) / Power circuit-breaker for trafo/generator/installation prot. (EC000228)   |  |    |           |
| Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Circuit breaker for power transformer, generator and system protection (ecl@ss8.1-27-37-04-09 [AJZ716010]) |  |    |           |
| Rated permanent current I <sub>u</sub>   |  | A  | 630       |
| Rated voltage  |  | V  | 690 - 690 |
| Rated short-circuit breaking capacity I <sub>cu</sub> at 400 V, 50 Hz  |  | kA | 150       |
| Overload release current setting   |  | A  | 315 - 630 |
| Adjustment range short-term delayed short-circuit release  |  | A  | 0 - 0     |


|   |   |   |
|---|---|---|
| Adjustment range undelayed short-circuit release        | A | 1260 - 5040                                       |
| Integrated earth fault protection                       |   | No  |
| Type of electrical connection of main circuit           |   | Screw connection                                  |
| Device construction                                     |   | Built-in device slide-in technique (withdrawable) |
| Suitable for DIN rail (top hat rail) mounting           |   | No  |
| DIN rail (top hat rail) mounting optional               |   | No  |
| Number of auxiliary contacts as normally closed contact |   | 0   |
| Number of auxiliary contacts as normally open contact   |   | 0   |
| Number of auxiliary contacts as change-over contact     |   | 0   |
| Switched-off indicator available                        |   | No  |
| With under voltage release                              |   | No  |
| Number of poles   |   | 3   |
| Position of connection for main current circuit         |   | Front side  |
| Type of control element                                 |   | Rocker lever                                      |
| Complete device with protection unit                    |   | Yes   |
| Motor drive integrated                                  |   | No  |
| Motor drive optional                                    |   | Yes   |
| Degree of protection (IP)                               |   | IP20  |

## Characteristics






Let-through current



Let-through energy

## Dimensions



- ① Blow out area, minimum clearance to adjacent parts
- ② Minimum clearance to adjacent parts



### Additional product information (links)

Temperature dependency, Derating

<http://ecat.moeller.net/flip-cat/?edition=HPLEN&startpage=17.172>

CurveSelect characteristics program

<http://www.eaton.eu/DE/Europe/Electrical/CustomerSupport/ConfigurationTools/CharacteristicsProgram/index.htm>